



Fortified Roof Documentation Requirements High Wind



 Photo of roof deck thickness of at least 7/16" (stamp on decking or measuring tape on side)




6 photos showing roof deck nailed down with 8d ring shank nails with the max. distance between nails being 6" and nails marked with marker or chalk



Photo showing dimensions of decking nail used (min. diameter 0.113 in. and min. length 2 3/8 in)



3 photos each of 4" roof deck tape & underlayment (see note at bottom for nailing requirements) or "peel n' stick" installation*



Drip edge installed with a 4" max spacing nail pattern***

No button caps in drip edge



Shingle/Metal used**



Screw spacing on metal roof



Installation of starter strips at eaves (minimum 8" wide)



Attic vents used (Model and installation)**



4 Finished elevation photos (front, back, left, and right side of the property).



*Synthetic felt must be nailed down 6" at the laps with at least 2 rows in the field spaced 12" apart. **For materials used a copy of the material invoice works as a substitute

*** Drip edge must be installed over underlayment